

**Aquarion Water Company of Massachusetts
PFAS Sampling Results**

Water System Name: Sheffield

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL PFAS6	Quarterly Average*	MassDEP MCL
Sheffield	Pike Well, 04G (POE)	Apr. 2022	ND	ND	ND	ND	ND	ND	ND	ND	20
		May 2022	ND	ND	ND	ND	ND	ND	ND	ND	20
		Jul. 2022	ND	ND	ND	ND	ND	ND	ND	ND	20
	Maple Ave Well, 05G (POE)	Apr. 2022	ND	ND	ND	ND	ND	ND	ND	ND	20
		May 2022	ND	ND	ND	ND	ND	ND	ND	ND	20
		Jul. 2022	ND	ND	ND	ND	ND	ND	ND	ND	20

Footnote:

*Compliance with the MCL is based on the quarterly average of all samples collected during the calendar quarter.

Definitions:

MassDEP - Massachusetts Department of Environmental Protection

MCL - Maximum Contaminant Level

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.