

**Aquarion Water Company of Massachusetts  
Historic PFAS Sampling Results**

**Town/City: Dover**

**Water System Name: Springdale Farms**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL PFAS6	Quarterly Average*	MassDEP MCL
Springdale Farms	Springdale Wells, (POE)	Oct. 2021	7.8	6.5	2.6	J	J	ND	16.8	17.8	20
		Nov. 2021	9.1	6.7	3.1	J	J	ND	18.9		
		Jan. 2022	6.1	5.8	2.5	J	J	ND	14.3		
		Feb. 2022	6.1	6.1	2.8	ND	ND	ND	15.1	13.0	20
		Mar. 2022	5.1	4.5	ND	ND	ND	ND	9.6		
		Apr. 2022	5.4	5.4	2.0	ND	ND	ND	12.8	13.8	20
		May 2022	7.2	6.2	2.0	J	J	ND	16.9		
		Jun. 2022	6.2	5.4	J	J	ND	ND	11.6		

**Footnotes:**

\*Compliance with the MCL is based on the quarterly average of all samples collected during the calendar quarter.

**Definitions:**

**J** - The result reported from the laboratory is below Minimum Reporting Level of 2 ppt, but greater than the Method Detection Limit. Per MassDEP, this value is not included in the compliance Total for PFAS6.

**MassDEP** - Massachusetts Department of Environmental Protection

**MCL** - Maximum Contaminant Level

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.